

Aquis Comfort Acoustic Luxury Vinyl Plank (LVP) Fire Resistance Rating Report



UB
TRADING

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

TEST REPORT

Client : UB Trading Pty Ltd
13 Kirkton Pl
Edensor Park NSW 2176

Test Number : 26-001732
Issue Date : 29/06/2026
Print Date : 29/06/2026

Sample Description Clients Ref : "Aquis Comfort Acoustic Flooring"
Luxury Vinyl Flooring Plank
Colour : Timber effect
End Use : Flooring
Nominal Composition : Vinyl
Nominal Thickness : 5mm



381426

83750

Page 1 of 2

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

Fiona McDonald
APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR



UB
TRADING

Proudly imported by UB Trading Pty Ltd.
For further information please visit: www.ubtrading.com.au
Contact: info@ubtrading.com.au

Aquis Comfort Acoustic Luxury Vinyl Plank (LVP) Fire Resistance Rating Report



UB
TRADING

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : UB Trading Pty Ltd
13 Kirkton Pl
Edensor Park NSW 2176

Test Number : 26-001732
Issue Date : 29/06/2026
Print Date : 29/06/2026

AS ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival 08-05-2026

Date Tested 26-06-2026

CHF Value	1	2	3	Mean
Length	8.9	10.4	8.7	9.3 kW/m ²
Width	9.5	-	-	- kW/m ²

Smoke Value	1	2	3	Mean
Length	129	89	191	136 %min
Width	129	-	-	- %min

Observations:

Melting Yes

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

381426

83750

Page 2 of 2

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

Fiona McDonald
APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc (Hons)
MANAGING DIRECTOR



UB
TRADING

Proudly imported by UB Trading Pty Ltd.
For further information please visit: www.ubtrading.com.au
Contact: info@ubtrading.com.au